



## กฎกระทรวง

กำหนดลักษณะอาคารประเภทอื่นที่ใช้ประกอบธุรกิจโรงแรม

พ.ศ. ๒๕๕๙

อาศัยอำนาจตามความในมาตรา ๕ (๓) แห่งพระราชบัญญัติควบคุมอาคาร พ.ศ. ๒๕๒๒ และมาตรา ๘ (๑) (๒) (๓) และ (๘) แห่งพระราชบัญญัติควบคุมอาคาร พ.ศ. ๒๕๒๒ ซึ่งแก้ไขเพิ่มเติมโดยพระราชบัญญัติควบคุมอาคาร (ฉบับที่ ๓) พ.ศ. ๒๕๔๓ รัฐมนตรีว่าการกระทรวงมหาดไทย โดยคำแนะนำของคณะกรรมการควบคุมอาคารออกกฎกระทรวงไว้ ดังต่อไปนี้

ข้อ ๑ กฎกระทรวงนี้ให้ใช้บังคับได้มีกำหนดห้าปี

ข้อ ๒ ในกรณีที่กฎกระทรวงนี้มิได้กำหนดเรื่องใดไว้ให้นำข้อกำหนดเรื่องนั้นตามกฎกระทรวงอื่น ข้อบัญญัติท้องถิ่น หรือประกาศของรัฐมนตรีที่ออกตามพระราชบัญญัติควบคุมอาคาร พ.ศ. ๒๕๒๒ ที่ใช้บังคับเป็นการทั่วไป มาใช้บังคับแก่อาคารตามกฎกระทรวงนี้โดยอนุโลม เว้นแต่ข้อกำหนดเกี่ยวกับบันไดหนีไฟให้ใช้บังคับตามที่กำหนดในกฎกระทรวงนี้

ข้อ ๓ กฎกระทรวงนี้ให้ใช้บังคับแก่อาคารที่มีอยู่ก่อนวันที่กฎกระทรวงนี้ใช้บังคับและจะเปลี่ยนการใช้อาคารมาประกอบธุรกิจโรงแรมตามกฎหมายว่าด้วยโรงแรม ดังต่อไปนี้

(๑) โรงแรมที่ให้บริการเฉพาะห้องพัก

(๒) โรงแรมที่ให้บริการห้องพักและห้องอาหาร หรือสถานที่สำหรับบริการอาหารหรือสถานที่สำหรับประกอบอาหาร

ข้อ ๔ การยื่นคำขอรับใบอนุญาตเปลี่ยนการใช้อาคารมาประกอบธุรกิจโรงแรมตามกฎกระทรวงนี้ ต้องดำเนินการให้แล้วเสร็จตามที่ได้รับอนุญาตภายในห้าปีนับแต่วันที่กฎกระทรวงนี้ใช้บังคับ

ในกรณีที่ต้องมีการตัดแปลงอาคารก่อนการขอรับใบอนุญาตเปลี่ยนการใช้อาคาร ให้ยื่นคำขอรับใบอนุญาตหรือแจ้งและดำเนินการตามมาตรา ๓๙ ทวิ เพื่อตัดแปลงอาคารภายในสองปีนับแต่วันที่กฎกระทรวงนี้ใช้บังคับ

ข้อ ๕ อาคารที่จะเปลี่ยนการใช้มาประกอบธุรกิจโรงแรมตามกฎหมายว่าด้วยโรงแรม ให้มีที่ว่างของอาคารไม่น้อยกว่า ๑๐ ใน ๑๐๐ ส่วนของพื้นที่ชั้นใดชั้นหนึ่งที่มากที่สุดของอาคาร และต้องมีลักษณะ ดังต่อไปนี้

- (๑) อาคารไม่เกินสองชั้นที่มีจำนวนห้องพักในอาคารหลังเดียวกันไม่เกิน ๑๐ ห้อง
- (ก) ช่องทางเดินในอาคารกว้างไม่น้อยกว่า ๑ เมตร
- (ข) บันไดกว้างไม่น้อยกว่า ๐.๙๐ เมตร และต้องมีระยะห่างตามแนวทางเดินไม่เกิน ๔๐ เมตร จากจุดที่ไกลสุดบนพื้นชั้นนั้น
- (ค) หน่วยน้ำหนักบรรทุกทุกจรสำหรับส่วนต่าง ๆ ของอาคารให้คำนวณโดยเฉลี่ยไม่ต่ำกว่า ๑๕๐ กิโลกรัมต่อตารางเมตร
- (ง) ติดตั้งเครื่องดับเพลิงแบบมือถือหรือเครื่องดับเพลิงยกหัวตามประเภท ขนาด และสมรรถนะตามมาตรฐานเครื่องดับเพลิงแบบมือถือหรือเครื่องดับเพลิงยกหัวของกรมโยธาธิการและผังเมือง ไม่น้อยกว่าชั้นละหนึ่งเครื่อง โดยต้องติดตั้งให้ส่วนบนสุดของตัวเครื่องสูงจากระดับพื้นอาคารไม่เกิน ๑.๕๐ เมตร ในที่มองเห็น สามารถอ่านข้อแนะนำการใช้ได้ และสามารถเข้าใช้สอยได้สะดวก
- (๒) อาคารที่ไม่ใช่อาคารตาม (๑) ที่มีจำนวนห้องพักในชั้นเดียวกันไม่เกิน ๒๐ ห้อง
- (ก) ช่องทางเดินในอาคารมีความกว้างไม่น้อยกว่า ๑.๒๐ เมตร
- (ข) หน่วยน้ำหนักบรรทุกทุกจรสำหรับอาคารให้เป็นไปตามกฎกระทรวงที่ออกตามมาตรา ๘ (๒) และ (๓) เว้นแต่หน่วยน้ำหนักบรรทุกทุกจรของบันไดและช่องทางเดินที่เปลี่ยนการใช้อาคารจากห้องแถว หรือตึกแถว หน่วยน้ำหนักบรรทุกทุกจรต้องไม่ต่ำกว่า ๒๐๐ กิโลกรัมต่อตารางเมตร
- (๓) อาคารที่ไม่ใช่อาคารตาม (๑) ที่มีจำนวนห้องพักในชั้นเดียวกันเกินกว่า ๒๐ ห้อง
- (ก) ช่องทางเดินในอาคารมีความกว้างไม่น้อยกว่า ๑.๕๐ เมตร
- (ข) หน่วยน้ำหนักบรรทุกทุกจรสำหรับอาคารให้เป็นไปตามกฎกระทรวงที่ออกตามมาตรา ๘ (๒) และ (๓) เว้นแต่หน่วยน้ำหนักบรรทุกทุกจรของบันไดและช่องทางเดินที่เปลี่ยนการใช้จากห้องแถว หรือตึกแถว หน่วยน้ำหนักบรรทุกทุกจรต้องไม่ต่ำกว่า ๒๐๐ กิโลกรัมต่อตารางเมตร
- (๔) เสาคาน ตง พื้น บันได โครงหลังคา และผนังของอาคารตั้งแต่สามชั้นขึ้นไป ต้องทำด้วยวัสดุถาวรที่เป็นวัสดุทนไฟ
- (๕) อาคารตั้งแต่สี่ชั้นขึ้นไปต้องมีบันไดหนีไฟที่มีลักษณะ ดังต่อไปนี้
- (ก) บันไดหนีไฟที่ไม่ใช่บันไดในแนวดิ่งซึ่งมีความเหมาะสมกับพื้นที่ของอาคารแต่ละชั้น เพื่อให้สามารถลำเลียงบุคคลทั้งหมดในอาคารออกนอกอาคารได้ภายในหนึ่งชั่วโมง
- (ข) บันไดหนีไฟภายในอาคารต้องมีผนังทุกด้านโดยรอบที่ทำด้วยวัสดุทนไฟได้ไม่น้อยกว่า ๓๐ นาที
- (ค) กรณีที่นำบันไดหลักมาเป็นบันไดหนีไฟหรือมีบันไดหนีไฟเพิ่มจากบันไดหลัก ช่องประตูสู่บันไดหนีไฟต้องเป็นบานเปิดทำด้วยวัสดุทนไฟได้ไม่น้อยกว่า ๓๐ นาที พร้อมติดตั้งอุปกรณ์ชนิดที่บังคับให้บานประตูปิดได้เองเพื่อป้องกันควันและเปลวไฟมิให้เข้าสู่บันไดหนีไฟ
- (ง) ต้องมีทางเดินไปยังบันไดหนีไฟโดยไม่มีสิ่งกีดขวาง
- (จ) ต้องมีความลาดชันของบันไดน้อยกว่า ๖๐ องศา

ข้อ ๖ การนำอาคารประเภทอื่นมาประกอบธุรกิจโรงแรมตามกฎหมายว่าด้วยโรงแรม ให้ใช้ข้อกำหนดเกี่ยวกับแนวอาคาร ระยะตั้งของอาคาร ระยะหรือระดับระหว่างอาคารกับอาคาร หรือเขตที่ดินของผู้อื่น หรือระหว่างอาคารกับถนน ตรอก ซอย ทางเท้า ทางหรือที่สาธารณะ และที่จอดรถยนต์ตามประเภทอาคารที่กฎหมายกำหนดในขณะที่ได้รับอนุญาตให้ก่อสร้างหรือดัดแปลงอาคารนั้น

ให้ไว้ ณ วันที่ ๑๑ สิงหาคม พ.ศ. ๒๕๕๙

พลเอก อนุพงษ์ เผ่าจินดา

รัฐมนตรีว่าการกระทรวงมหาดไทย

หมายเหตุ :- เหตุผลในการประกาศใช้กฎกระทรวงฉบับนี้ คือ โดยที่มีการนำอาคารประเภทอื่นมาให้บริการที่พักแก่ประชาชนเป็นการทั่วไป ซึ่งลักษณะและโครงสร้างของอาคารที่มีอยู่เดิมไม่สอดคล้องกับอาคารที่จะนำมาประกอบธุรกิจโรงแรมตามที่กฎหมายว่าด้วยการควบคุมอาคารกำหนด จึงทำให้อาคารดังกล่าวไม่สามารถขอรับใบอนุญาตเพื่อประกอบธุรกิจโรงแรมตามกฎหมายว่าด้วยโรงแรมได้ เพื่อให้อาคารที่มีอยู่แล้วซึ่งได้มีการปรับปรุงแก้ไขให้มีลักษณะหรือมาตรฐานความปลอดภัยของอาคารตามที่กฎหมายกำหนดสามารถขออนุญาตเปลี่ยนการใช้อาคารเพื่อประกอบธุรกิจโรงแรมได้ จึงจำเป็นต้องออกกฎกระทรวงนี้

**Ministerial Regulation**  
**Characteristics of Different Building Types Used**  
**in the Hotel Business, B.E. 2559 (2016)<sup>1</sup>**

---

By virtue of Section 5(3) of the Building Control Act B.E. 2522 (1979) and Section 8 (1) (2) (7) and (8) of the Building Control Act B.E. 2522 (1979), as amended by the Building Control Act (No. 3) B.E. 2543 (2000), the Minister of Interior, by the advice of the Building Control Committee, issues the Ministerial regulation as follow:

Clause 1 This Ministerial Regulation shall remain in effect for a period of five years.

Clause 2 In cases where any matter is not specified in this Ministerial Regulation, the provisions of other Ministerial Regulations, local regulations, or announcements issued by the Minister under the Building Control Act B.E. 2522 (1979), applicable in general, shall be applied to buildings under this Ministerial Regulation mutatis mutandis. However, the provisions regarding fire escape stairs shall be enforced as specified in this Ministerial Regulation.

Clause 3 This Ministerial Regulation shall apply to existing buildings, prior to the effective date of this Ministerial Regulation, that change their use to operate a hotel business in accordance with the hotel law, as follows:

(1) Hotels only provide room stay service.

(2) Hotels provide room stay service with a dining room or dining and cooking areas.

---

1

Clause 4 Applicants seeking a license to change the use of a building to operate a hotel business in accordance with this Ministerial Regulation shall complete the necessary actions within five years from the effective date of this Ministerial Regulation. In cases where building modifications are required before applying for a permit to change the building's use, the applicant shall submit an application, obtain a license, or provide notification in accordance with Section 39 bis to modify the building within two years from the effective date of this Ministerial Regulation.

Clause 5 Buildings that will be modified or changed their use to operate as a hotel under the law of hotel shall have available space for no less than 10 in 100 parts of the largest floor space of the building and shall have the following properties:

(1) Buildings with no more than two floors and not exceeding a certain number of rooms:

(A) The building corridors shall be no less than 1 meter wide.

(B) The width of the stairs shall be no less than 0.90 meters, and the distance along the walkway shall not exceed 40 meters from the farthest point on the floor.

(C) The live load weight for other parts of the building shall be calculated as an average, not less than 150 kilograms per square meter.

(D) Hand-held or portable fire extinguishers shall be installed in accordance with the type, size, and capacities standards set by the Department of Public Works and Town & Country Planning. There shall be at least one fire extinguisher per floor, installed in a way that the top of the machine does not exceed 1.50 meters above the floor level, clearly visible, with readable instructions for usage, and easily accessible.

(2) Buildings not falling under the criteria mentioned in (1) and with the number of rooms on the same floor not exceeding 20:

(A) The building corridors shall have a width of not less than 1.20 meters.

(B) The live load weight for the building shall be in accordance with the Ministerial Regulation issued under Section 8 (2) and Subsection (3). However, for buildings that change their use from row houses or townhouses, the load weight shall not be less than 200 kilograms per square meter, excluding the load weight of stairs and corridors.

(3) Buildings not falling under the criteria mentioned in Subsection (1) and with the number of rooms on the same floor exceeding 20 rooms:

(A) The building corridors shall have a width of not less than 1.50 meters.

(B) The live load weight for the building shall be in accordance with the Ministerial Regulation issued under Section 8(2) and Subsection (3). Buildings that change their usage from row houses or townhouses, The live load weight of stairs and walkways shall not be less than 200 kilograms per square meter.

(4) Buildings with three or more floors shall have Pillars, beams, joists, floors, stairs, roof structures, and walls of the buildings with three or more floors shall be made by fire - resistant materials

(5) Buildings with four or more floors shall have fire escape stairs that meet the following criteria:

(A) The fire escape stairs shall not be vertical stairs and shall be suitable for the area of each floor of the building to allow the evacuation of all individuals within one hour.

(B) The fire escape stairs inside the building shall have walls on all sides made of fire-resistant materials that can withstand at least 30 minutes of fire.

(C) If the main staircase is used as a fire escape or if there is an additional fire escape from the main staircase, the door to the fire escape shall be a self-closing door made of fire-resistant materials capable of withstanding at least 30 minutes of fire. The door should be equipped with a device that ensures its closure to prevent smoke and flame from entering the fire escape.

(D) There shall be unobstructed access to the fire escape stairs.

(E) The stairs shall have a slope of less than 60 degrees.

Clause 6: When converting other types of buildings to operate a hotel business in accordance with the hotel law, the building line regulations, vertical distance or level between buildings or between a building and land belonging to others, or between a building and a road, alley, sidewalk, or public place, as well as car park requirements, shall be complied with in accordance with the building type prescribed by law, while obtaining permission for construction or modification.

Given on 11<sup>th</sup> Day of August B.E. 2559 (2016)

General Anupong Paochinda

Minister of Interior